



CITY OF LAGUNA HILLS ORDINANCE SUMMARY CERTIFICATION

STATE OF CALIFORNIA)
COUNTY OF ORANGE) ss.
CITY OF LAGUNA HILLS)

I, MELISSA AU-YEUNG, City Clerk of the City of Laguna Hills, California,

DO HEREBY CERTIFY that the attached is a true and correct copy of:

ORDINANCE NO. 2016-8

AN ORDINANCE OF THE CITY OF LAGUNA HILLS, CALIFORNIA, AMENDING CHAPTER 5-16 (FIRE CODE) OF TITLE 5 (HEALTH AND SANITATION) OF THE LAGUNA HILLS MUNICIPAL CODE AND ADOPTING BY REFERENCE THE 2016 EDITION OF THE CALIFORNIA FIRE CODE INCLUDING APPENDICES B, BB, C, CC, AND H, TOGETHER WITH CERTAIN AMENDMENTS, ADDITIONS, AND DELETIONS THERETO.

This Ordinance was adopted by the City Council of the City of Laguna Hills, California, at a regular meeting thereof on the 13th day of December 2016, by the following vote:

AYES: Council Members Gilbert, Heft, Kogerman, Mayor Pro
 Tempore Carruth, and Mayor Sedgwick

NOES: None

ABSENT: None

ABSTAIN: None



MELISSA AU-YEUNG, CITY CLERK

Dated this 14th day of December 2016.

ORDINANCE NO. 2016-8

AN ORDINANCE OF THE CITY OF LAGUNA HILLS, CALIFORNIA, AMENDING CHAPTER 5-16 (FIRE CODE) OF TITLE 5 (HEALTH AND SANITATION) OF THE LAGUNA HILLS MUNICIPAL CODE AND ADOPTING BY REFERENCE THE 2016 EDITION OF THE CALIFORNIA FIRE CODE INCLUDING APPENDICES B, BB, C, CC, AND H, TOGETHER WITH CERTAIN AMENDMENTS, ADDITIONS, AND DELETIONS THERETO.

WHEREAS, pursuant to California Government Code Section 50022.1 *et seq.* the City of Laguna Hills ("City") may adopt by reference the 2016 California Fire Code, based on the International Fire Code, 2015 Edition (including appendices), published by the International Code Council (ICC), as adopted by the State of California pursuant to Title 24, Part 9 of the California Code of Regulations; and

WHEREAS, California Health & Safety Code Section 17958.5 authorizes cities to adopt the codes contained in Title 24 of the California Code of Regulations with changes and modifications determined to be reasonably necessary because of local climatic, topographic or geologic conditions; and

WHEREAS, the City desires to adopt the 2016 California Fire Code including Appendices B, BB, C, CC and H, based on the International Fire Code, 2015 Edition, published by International Code Council (ICC), as adopted by Title 24, Part 9 of the California Code of Regulations ("Fire Code") with necessary amendments to assure the Code is tailored to the particular fire protection needs of the City as required by local climatic, topographic and geologic conditions and assure that a maximum level of fire protection is provided to residents, businesses and other occupants; and

WHEREAS, on November 22, 2016, the City Council introduced this Ordinance for first reading at a regular meeting of the City Council, and set a public hearing and second reading of the Ordinance for December 13, 2016; and

WHEREAS, pursuant to California Government Code Section 6066, the City published notice of the aforementioned public hearing; and

WHEREAS, any and all other legal prerequisites relating to the adoption of this Ordinance have occurred;

THE CITY COUNCIL OF THE CITY OF LAGUNA HILLS, CALIFORNIA, DOES
ORDAIN AS FOLLOWS:

SECTION 1. Findings. The City Council hereby finds that the proposed amendments to the 2016 California Fire Code are reasonably necessary because of local climatic, geologic or topographic conditions, and adopts the findings provided below to support the modifications to the 2016 California Fire Code.

I. Climatic Conditions

A. Orange County located in a semi-arid Mediterranean type climate. It annually experiences extended periods of high temperatures with little or no precipitation. Hot, dry (Santa Ana) winds, which may reach speeds of 70 M.P.H. or greater, are also common to the area. These climatic conditions cause extreme drying of vegetation and common building materials. Frequent periods of drought and low humidity add to the fire danger. This predisposes the area to large destructive fires (conflagration). In addition to directly damaging or destroying buildings, these fires are also prone to disrupt utility services throughout the County. Obstacles generated by a strong wind, such as fallen trees, street lights and utility poles will greatly impact the response time to reach an incident scene.

B. The climate alternates between extended periods of drought and brief flooding conditions. Flood conditions may affect the Orange County fire Authority's ability to respond to a fire or emergency condition. Floods also disrupt utility services to buildings and facilities within the County.

C. Water demand in this densely populated area far exceeds the quantity supplied by natural precipitation; and although the population continues to grow, the already-taxed water supply does not. California is projected to increase in population by nearly 10 million over the next quarter of a century with 50 percent of that growth centered in Southern California. Due to storage capacities and consumption, and a limited amount of rainfall future water allocation is not fully dependable. This necessitates the need for additional and on-site fire protection features

D. These dry climatic conditions and winds contribute to the rapid spread of even small fires originating in high-density housing or vegetation. These fires spread very quickly and create a need for increased levels of fire protection. The added protection of fire sprinkler systems and other fire protection features will supplement normal fire department response by providing immediate protection for the building occupants and by containing and controlling the fire spread to the area of origin. Fire sprinkler systems will also reduce the use of water for firefighting by as much as 50 to 75 percent.

II. Topographical conditions

A. Natural; slopes of 15 percent or greater generally occur throughout the foothills of Orange County. The elevation change caused by the hills creates the geological foundation on which communities with Orange County is built and will continue to build. With much of the populated flatlands already built upon, future growth will occur on steeper slopes and with greater constraints in terrain.

B. Traffic and circulation congestion is an artificially created, obstructive topographical condition, which is common throughout Orange County.

C. These topographical conditions combine to create a situation that places fire department response time to fire occurrences at risk, and makes it necessary to provide automatic on-site fire-extinguishing systems and other protection measures to protect occupants and property.

III. Geological Conditions

A. The Orange County region is a densely populated area that has buildings constructed over and near a vast and complex network of faults that are believed to be capable of producing future earthquakes similar or greater in size than the 1994 Northridge and the 1971 Sylmar earthquakes. Earthquake faults run along the northeast and southwest boundaries of Orange County. The Newport-Inglewood Fault, located within Orange County was the source of the destructive 1933 Long Beach earthquake (6.3 magnitude) which took 120 lives and damaged buildings in an area from Laguna Beach to Marina Del Rey to Whittier. In December 1989, another earthquake occurred in the jurisdiction of Irvine at an unknown fault line. Regional planning for reoccurrence of earthquakes is recommended by the state of California, Department of Conservation.

B. Previous earthquakes have been accompanied by disruption of traffic flow and fires. A severe seismic event has the potential to negatively impact any rescue or fire suppression activities because it is likely to create obstacles similar to those indicated under the high wind section above. The October 17, 1989, Santa Cruz earthquake resulted in one major fire in the Marina District (San Francisco). When combined with the 34 other fires locally and over 500 responses, the department was taxed to its fullest capabilities. The Marina fire was difficult to contain because mains supplying water to the district burst during the earthquake. This situation creates the need for both additional fire protection and automatic on-site fire protection for building occupants. State Department of Conservation noted in their 1988 report (Planning Scenario on a Major Earthquake on the Newport-Inglewood Fault Zone, page 59), "unfortunately, barely meeting the minimum earthquake standards of building codes places a building on the verge of being legally unsafe."

C. Road circulation features located throughout the County also make amendments reasonably necessary. Located through the County are major roadways, highways and flood control channels that create barriers and slow response times. Hills, slopes, street and storm drain design, accompanied by occasional heavy rainfall, causes roadway flooding and landslides and at times may make an emergency access route impassable. There are areas in Orange County that naturally have extended emergency response times that exceed the 5 minute goal.

D. Soils throughout the County possess corrosive properties that reduce the expected usable life of water services when metallic pipes are in contact with soils.

Due to the topographical conditions of sprawling development separated by waterways and narrow and congested streets and the expected infrastructure damage inherent in seismic zones described above, it is prudent to rely on automatic fire sprinkler systems to mitigate extended fire department response time and keep fires manageable with reduced fire flow (water) resources available for a given structure. Additional fire protection is also justified to match the current resources of firefighting equipment and personnel within the Orange County Fire Authority.

The findings above are applicable to amendments to the 2016 California Fire Code and the International Fire Code, 2015 Edition as follows:

CODE SECTION	TITLE (Clarification)	FINDINGS
109.4	Violation penalties	Administrative
109.4.2	Infraction & Misdemeanor	Administrative
202	General definitions	Administrative
304.1.2	OCFA Vegetation Management	I
305.6	Hazardous conditions	I & II
305.7	Disposal of rubbish	I & II
307	Fire Pits, Fire Rings, & Outdoor Fireplaces	Administrative
307.6.1	Gas-fueled devices	I & II
307.6.2	Devices using wood or fuels other than natural gas or LPG	I & II
307.6.2.1	Where prohibited	I & II
309.2.1	Indoor charging of electric cars	Administrative
320	Fuel modification requirements for new construction	I
321	Clearance of brush or vegetation growth from roadways	I
322	Unusual circumstances	Administrative

323	Use of equipment	I
323.1	Spark arresters	I
324	Sky Lanterns or similar devices	I & II
407.5	Hazardous material inventory statement	I & II
501.1	Scope	Administrative, I, II & III
510.1	Emergency responder radio coverage	Administrative
510.4.2.2	Technical Criteria	Administrative
510.5.1	Approval prior to installation	Administrative
510.5.2	Minimum qualification of personnel	Administrative
510.5.3	Acceptance test procedure	Administrative
510.6.1	Testing and proof of compliance	Administrative
903.2	Where required (Sprinklers)	I, II & III
903.2.8	Group R (Sprinklers)	I, II & III
903.3.5.3	Hydraulically calculated systems	I & II
2801.2	Permit	Administrative
2808.2	Storage site	Administrative
2808.3	Size of piles	I
2808.4	Pile separation	I
2808.7	Pile fire protection	I
2808.9	Material-handling equipment	I
2808.11	Temperature control	I
2808.11.1	Pile temperature control	I
2808.11.2	New material temperature control	I
2808.12	Water availability for piles	I
2808.13	Tipping area	I
2808.14	Emergency contact	Administrative
4906.3	OCFA Vegetation Management Guideline	I
4908	Fuel modification requirements for new construction	I
5001.5.2	Hazardous materials inventory statement	Administrative
5003.1.1.1	Extremely hazardous substances	I & III
5608.2	Retail fireworks	Administrative
5608.3	Application for permit	Administrative
Chapter 80	Reference Standards	N/A
	2016 NFPA 13 (Sprinkler Systems)	Administrative, II & III
	2016 NFPA 13-D (Single Family Sprinkler Systems)	I & II
	2013 NFPA 14 (Standpipe Systems)	Administrative
	2016 NFPA 24 (Underground Water Supply Systems)	Administrative & III

SECTION 2. Section 5-16.010 of the Laguna Hills Municipal Code is hereby amended and restated in its entirety to read as follows:

5-16.010 Adoption of the California Fire Code and International Fire Code

The 2016 California Fire Code, including Appendices B, BB, C, CC, and H based on the International Fire Code, 2015 Edition, published by the International Code Council (ICC), and the whole of the International Fire Code, 2015 Edition, together with the amendments provided in this chapter, are hereby adopted and incorporated by reference, as though set forth at length herein, as the Fire Code of the City of Laguna Hills for the purpose of prescribing regulations governing conditions hazardous to life and property from fire, explosions.. Not less than one copy of said codes has been filed in the office of the City Clerk and shall be made available for public inspection.

SECTION 3. Section 5-16.030 of the Laguna Hills Municipal Code is hereby amended and restated in its entirety to read as follows:

5-16.030 Amendments to the California Fire Code

Chapter 1 Scope and Administration is adopted in its entirety with the following amendments:

Section 109.4 Violation penalties is hereby revised to read as follows:

109.4 Violation penalties. Persons who shall violate a provision of this code or shall fail to comply with any of the requirements thereof or shall fail to comply with any issued orders or notices or who shall erect, install, alter, repair or do work in violation of the approved construction documents or directive of the fire code official, or of a permit or certificate used under provisions of this code, shall result in penalties assessed as prescribed in the OCFA Prevention Field Services adopted fee schedule. Each day that a violation continues after due notice has been served shall be deemed a separate offense.

Section 109.4.2 Infraction and misdemeanor is hereby added as follows:

109.4.2 Infraction and misdemeanor. Persons operating or maintaining any occupancy, premises or vehicle subject to this code that shall permit any fire or

life safety hazard to exist on premises under their control shall be guilty of an infraction. Persons who fail to take immediate action to abate a fire or life safety hazard when ordered or notified to do so by the chief or a duly authorized representative are guilty of a misdemeanor.

Chapter 2 Definitions is adopted in its entirety with the following amendments:

Section 202 General Definitions is hereby revised by adding "OCFA," "Sky Lantern," and "Spark Arrester" as follows:

202 General Definitions

OCFA: Orange County Fire Authority, fire authority having jurisdiction.

SKY LANTERN. An airborne lantern typically made of paper, Mylar, or other lightweight material with a wood, plastic, or metal frame containing a candle, fuel cell, or other heat source that provides buoyancy.

SPARK ARRESTER. A listed device constructed of noncombustible material specifically for the purpose of meeting one of the following conditions:

1. Removing and retaining carbon and other flammable particles/debris from the exhaust flow of an internal combustion engine in accordance with California Vehicle Code Section 38366.
2. Fireplaces that burn solid fuel in accordance with California Building Code Chapter 28.

Chapter 3 General Requirements is adopted in its entirety with the following amendments:

Section 304.1.2 Vegetation is hereby revised to read as follows:

304.1.2 Vegetation. Type, amount, or arrangement of weeds, grass, vines or other growth that is capable of being ignited and endangering property needing to comply with OCFA Guidelines, shall be cut, thinned, and removed by the owner or occupant of the premises in accordance with OCFA Guideline C-05 "Vegetation Management Guideline—Technical Design for New Construction, Fuel Modification Plans, and Maintenance Program. Vegetation

clearance requirement in urban-wildland interface areas shall be in accordance with Chapter 49.

Section 305.6 Hazardous Conditions is hereby added as follows:

305.6 Hazardous conditions. Outdoor fires are not allowed when predicted sustained winds exceed 8 MPH during periods when relative humidity is less than 25%, or a red flag condition has been declared or public announcement is made, when an official sign was caused to be posted by the fire code official, or when such fires present a hazard as determined by the fire code official.

Section 305.7 Disposal of rubbish is hereby added as follows:

305.7 Disposal of rubbish. Rubbish, trash or combustible waste material shall be burned only within an approved incinerator and in accordance with Section 307.2.1.

Section 307 OPEN BURNING, RECREATIONAL FIRES AND PORTABLE OUTDOOR FIREPLACES is hereby revised to read as follows:

SECTION 307 OPEN BURNING, RECREATIONAL FIRES, FIRE PITS, FIRE RINGS, AND PORTABLE OUTDOOR FIREPLACES

Sections 307.6 Outdoor Fireplaces, Fire Pits, Fire Rings, or similar devices used at Group R Occupancies is hereby added as follows:

307.6 Outdoor Fireplaces, Fire Pits, Fire Rings, or similar devices used at Group R Occupancies. Outdoor fireplaces, fire pits, fire rings, or similar exterior devices used at Group R shall comply with this section.

Exception: Barbeques, grills, and other portable devices intended solely for cooking.

Section 307.6.1 Gas-fueled devices is hereby added as follows:

307.6.1 Gas-fueled devices. Outdoor fireplaces, fire pits and similar devices fueled by natural gas or liquefied-petroleum gas are allowed when approved by the Building Department and the device is designed to only burn a gas flame and not wood or other solid fuel. At R-3 occupancies, combustible construction shall not be located within three feet of an atmospheric column

that extends vertically from the perimeter of the device. At other R occupancies, the minimum distance shall be ten feet. Where a permanent Building Department approved hood and vent is installed, combustible construction may encroach upon this column between the bottom of the hood and the vent opening. Where chimneys or vents are installed, they shall have a spark arrester as defined in Section 202.

Section 309.2.1 Indoor charging of electric carts/cars is hereby added as follows:

309.2.1 Indoor charging of electric carts/cars. Indoor charging of electric carts/cars where the combined volume of all battery electrolyte exceeds 50 gallons shall comply with following:

1. Spill control and neutralization shall be provided and comply with Section 608.5.
2. Room ventilation shall be provided and comply with Section 608.6.1
3. Signage shall be provided and comply with Section 608.7.1
4. Smoke detection shall be provided and comply with Section 608.9.

Section 320 Fuel Modification Requirements for New Construction is hereby added as follows:

320 Fuel Modification Requirements for New Construction. All new structures and facilities adjoining land containing hazardous combustible vegetation shall be approved and in accordance with the requirements of OCFA Guideline C-05 "Vegetation Management Guideline – Technical Design for New Construction Fuel Modification Plans and Maintenance Program."

Section 321 Clearance of brush or vegetation growth from roadways is hereby added as follows:

321 Clearance of brush or vegetation growth from roadways. The fire code official is authorized to cause areas within 10 feet (3048 mm) on each side of portions of highways and private streets which are improved, designed or ordinarily used for vehicular traffic, to be cleared of flammable vegetation and other combustible growth. Measurement shall be from the flow-line or the end of the improved edge of the roadway surfaces.

Exception: Single specimens of trees, ornamental shrubbery or cultivated ground cover such as green grass, ivy, succulents or similar plants used as

ground covers, provided that they do not form a means of readily transmitting fire.

Section 322 Unusual Circumstances is hereby added as follows:

322 Unusual circumstances. The fire code official may suspend enforcement of the vegetation management requirements and require reasonable alternative measures designed to advance the purpose of this code if determined that in any specific case that any of the following conditions exist:

1. Difficult terrain.
2. Danger of erosion.
3. Presence of plants included in any state and federal resources agencies, California Native Plant Society and county-approved list of wildlife, plants, rare, endangered and/or threatened species.
4. Stands or groves of trees or heritage trees.
5. Other unusual circumstances that make strict compliance with the clearance of vegetation provisions undesirable or impractical.

Section 323 Use of Equipment is hereby added as follows:

323 Use of equipment. Except as otherwise provided in this section, no person shall use, operate, or cause to be operated in, upon or adjoining any hazardous fire area any internal combustion engine which uses hydrocarbon fuels, unless the engine is equipped with a spark arrester as defined in Section 202 maintained in effective working order, or the engine is constructed, equipped and maintained for the prevention of fire.

Exceptions:

1. Engines used to provide motor power for trucks, truck tractors, buses, and passenger vehicles, except motorcycles, are not subject to this section if the exhaust system is equipped with a muffler as defined in the Vehicle Code of the State of California.
2. Turbocharged engines are not subject to this section if all exhausted gases pass through the rotating turbine wheel, there is no exhaust bypass to the atmosphere, and the turbocharger is in good mechanical condition

Section 323.1 Spark Arresters is hereby added as follows:

323.1 Spark arresters. Spark arresters shall comply with Section 202, and when affixed to the exhaust system of engines or vehicles subject to Section

323 shall not be placed or mounted in such a manner as to allow flames or heat from the exhaust system to ignite any flammable material.

Section 324 Sky Lanterns or similar devices is hereby added as follows:

324 Sky Lanterns or similar devices. The ignition and/or launching of a Sky Lantern or similar device is prohibited.

Chapter 4: Emergency Planning and Preparedness. Only the following sections and subsections of Chapter 4 are enacted:

401
401.3.4
401.9
402
403.2
404.5 – 404.6.6
407

Section 407.5 is revised to read as follows:

407.5 Hazardous Materials Inventory Statement. Where required by the fire code official, each application for a permit shall include OCFA's Chemical Classification Packet in accordance with Section 5001.5.2.

Chapter 5 Fire Service Features is adopted in its entirety with the following amendments:

Section 501.1 Scope is revised to read as follows:

501.1 Scope. Fire service features for buildings, structures and premises shall comply with this chapter and, where required by the fire code official, with OCFA Guideline B-09, "Fire Master Plan for Commercial & Residential Development." Fire service features for buildings, structures and premises located in State Responsibility Areas shall also comply with OCFA Guideline B-09a, "Fire Safe Development in State Responsibility Areas."

Section 510.1 Emergency responder radio coverage is revised to read as follows:

510.1 Emergency responder radio coverage in new buildings. All new buildings shall have approved radio coverage for emergency responders within the building based upon the existing coverage levels of the public safety communication systems of the jurisdiction at the exterior of the building. This section shall not require improvement of the existing public safety communication systems. The Emergency Responder Radio Coverage System shall comply with the local authority having jurisdiction's ordinance and this code.

Exceptions:

1. Where it is determined by the fire code official that the radio coverage system is not needed.
2. In facilities where emergency responder radio coverage is required and such systems, components or equipment required could have a negative impact on the normal operations of that facility, the fire code official shall have the authority to accept an automatically activated emergency radio coverage system.

This section shall not apply to the following:

1. Existing buildings or structures, unless required by the Building Official and OCFA for buildings and structures undergoing extensive remodel and/or expansion.
2. Elevators.
3. Structures that are three stories or less without subterranean storage or parking and that do not exceed 50,000 square feet on any single story.
4. Wood-constructed residential structures four stories or less without subterranean storage or parking that are not built integral to an above ground multi-story parking structure.
5. Should construction that is three stories or less that does not exceed 50,000 square feet on any single story include subterranean storage or parking, then this ordinance shall apply only to the subterranean areas.

Section 510.2 Emergency responder radio coverage in existing buildings is deleted without replacement:

Section 510.4.2.2 Technical criteria is revised to read as follows:

510.4.2.2 Technical criteria. The fire code official shall maintain a document providing the specific technical information and requirements for the emergency responder radio coverage system. This document shall contain, but not be limited to, the various frequencies required, the location of radio

sites, effective radiated power of radio sites, and other supporting technical information.

1. The frequency range supported from the 800 MHz Countywide Communications System shall be 851-869 MHz (base transmitter frequencies).
2. The frequency range supported to the 800 MHz Countywide Communications System shall be 806-824 MHz (radio field transmit frequencies).
3. A public safety radio amplification system shall include filters to reject frequencies below 851 MHz and frequencies above 869 MHz by a minimum of 35dB.
4. All system components must be 100 percent compatible with analog and digital modulations after installation without adjustments or modifications. The systems must be capable of encompassing the frequencies stated herein and capable of future modifications to a frequency range subsequently established by the jurisdiction.
5. Active devices shall have a minimum of -50 dB 3rd order intermodulation protection.
6. All active in-building coverage devices shall be FCC Part 90 Type Certified

Section 510.5.1 Approval prior to installation is revised to read as follows:

510.5.1 Approval prior to installation. Amplification systems capable of operating on frequencies licensed to any public safety agency by the FCC shall not be installed without prior plan submittal, coordination and approval from Orange County Communications and a copy of the approved plan provided to of the fire and building code officials.

Section 510.5.2 Minimum qualification of personnel is revised to read as follows:

510.5.2 Minimum qualifications of personnel. The minimum qualifications of the system designer and lead installation personnel shall include both of the following:

1. A valid FCC-issued general radio operator's license.
2. Certification of in-building system training issued by a nationally recognized organization, school or a certificate issued by the manufacturer of the equipment being installed.

Section 510.5.3 Acceptance test procedure item 7 is revised to read as follows:

510.5.3 Acceptance test procedure. When an emergency responder radio coverage system is required, and upon completion of installation, the building owner shall have the radio system tested to ensure that two-way coverage on each floor of the building is not less than 90 percent. The test procedure shall be conducted as follows: ...

7. As part of the installation a spectrum analyzer or other suitable test equipment shall be utilized to ensure spurious oscillations are not being generated by the subject signal booster. This test shall be conducted at the time of installation and subsequent annual inspections by the FCC licensed technician hired by the property owner and an OCSD/Communications Division FCC-certified technician.

Section 510.6.1 Testing and proof of compliance is revised to read as follows:

510.6.1 Testing and proof of compliance.

The owner of the building or their representative shall have the emergency responder radio coverage system ~~shall be~~ inspected and tested annually or where structural changes occur including additions or remodels that could materially change the original field performance tests. Testing shall consist of the following:

1. In-building system components shall be tested to determine general functional operability.
2. Signal boosters shall be tested to ensure that the gain is the same as it was upon initial installation and acceptance.
3. Backup batteries and power supplies shall be tested under load of a period of one hour to verify that they will properly operate during an actual power outage. If within the 1-hour test period the battery exhibits symptoms of failure, the test shall be extended for additional 1-hour periods until the integrity of the battery can be determined.
4. Other active components shall be checked to verify operation within the manufacturer's specifications.
5. If noncompliance is found, the FCC licensed technician will assess improvements necessary and provide such information to OCSD Communications and the fire and building code officials.
6. At the conclusion of the testing, a certification report, which shall verify compliance with Section 510.5.3, shall be submitted to OCSD Communications and the fire and building code officials.

Chapter 9 Fire Protection Systems is adopted in its entirety with the following amendments:

Section 903.2 Where required is hereby revised to read as follows:

903.2 Where required. Approved automatic sprinkler systems in buildings and structures shall be provided when one of the following conditions exists:

1. **New buildings:** Notwithstanding any applicable provisions of Sections 903.2.1 through 903.2.19, an automatic fire-extinguishing system shall also be installed in all occupancies when the total building area exceeds 5,000 square feet as defined in Section 202, regardless of fire areas or allowable area, or is more than two stories in height.

Exception: Subject to approval by the Fire Code Official, open parking garages in accordance with Section 406.5 of the California Building Code.

2. **Existing Buildings:** Notwithstanding any applicable provisions of this code, an automatic sprinkler system shall be provided in an existing building when an addition occurs and one of the following conditions exists:

- a. When an addition is 33% or more of the existing building area, and the resulting building area exceeds 5000 square feet
- b. When an addition exceeds 2000 square feet and the resulting building area exceeds 5000 square feet.
- c. An additional story is added above the second floor regardless of fire areas or allowable area.

Exception: Additions to Group R-3 occupancies shall comply with Section 903.2.8 (2).

Section 903.2.8 Group R is hereby revised to read as follows:

903.2.8 Group R. An automatic sprinkler system installed in accordance with Section 903.3 shall be provided throughout all buildings with a Group R fire area as follows:

1. **New Buildings:** An automatic sprinkler system shall be installed throughout all new buildings.

2. **Existing R-3 Buildings:** An automatic sprinkler system shall be installed throughout when one of the following conditions exists:
- a. When an addition is 33% or more of the existing building area as defined in Section 202, and greater than 1000 square feet within a two year period; or,
 - b. An addition when the existing building is already provided with automatic sprinklers; or,
 - c. When an existing Group R Occupancy is being substantially renovated, and where the scope of the renovation is such that the Building Code Official determines that the complexity of installing a sprinkler system would be similar as in a new building.

Exceptions:

1. Existing Group R-3 occupancies converted to Group R-3.1 occupancies and not housing bedridden clients, not housing nonambulatory clients above the first floor, and not housing clients above the second floor.
2. Existing Group R-3 occupancies converted to Group R-3.1 occupancies housing only one bedridden client and complying with Section 435.8.3.3 of the California Building Code.
3. Pursuant to Health and Safety Code, Section 13113, occupancies housing ambulatory children only, none of whom are mentally ill children or children with intellectual disabilities, and the buildings or portions thereof in which such children are housed are not more than two stories in height, and building or portions thereof housing such children have an automatic fire alarm system activated by approved smoke detectors.
4. Pursuant to Health and Safety Code, Section 13143.6, occupancies licensed for protective social care which house ambulatory clients only, none of whom is a child (under the age of 18 years), or who is elderly (65 years of age or over).

When not used in accordance with Section 504.2 or 506.3 of the California Building Code, an automatic sprinkler system installed in accordance with Section 903.3.1.2 shall be allowed in Group R-2.1 occupancies.


An automatic sprinkler system designed in accordance with Section 903.3.1.3 shall not be utilized in Group R-2.1 or R-4 occupancies.

Section 903.3.5.3 Hydraulically calculated systems is hereby added as follows:

903.3.5.3 Hydraulically calculated systems. The design of hydraulically calculated fire sprinkler systems shall not exceed 90% of the water supply capacity.

Exception: When static pressure exceeds 100 psi, and when required by the fire code official, the fire sprinkler system shall not exceed the water supply capacity specified by Table 903.3.5.3.

**TABLE 903.3.5.3
Hydraulically Calculated Systems**



Chapter 11 Construction Requirements for Existing Buildings. Only the following sections and subsections of Chapter 11 are enacted:

- 1103.7
- 1103.7.3
- 1103.7.3.1
- 1103.7.8 – 1103.7.8.2
- 1103.7.9 – 1103.7.9.10
- 1103.8 – 1103.8.5.3
- 1107
- 1113
- 1114
- 1115
- 1116

Chapter 20 Aviation Facilities is adopted in its entirety without amendments.

Chapter 21 Dry Cleaning is adopted in its entirety without amendments.

Chapter 22 Combustible Dust-Producing Operations is adopted in its entirety without amendments.

Chapter 23 Motor Fuel-Dispensing Facilities and Repair Garages is adopted in its entirety without amendments.

Chapter 24 Flammable Finishes is adopted in its entirety without amendments.

Chapter 25 Fruit and Crop Ripening is deleted in its entirety.

Chapter 26 Fumigation and Insecticidal Fogging is deleted in its entirety.

Chapter 27 Semiconductor Fabrication Facilities is adopted in its entirety without amendments.

Chapter 28 Lumber Yards and Agro-Industrial, Solid Biomass and Woodworking Facilities is adopted in its entirety with the following amendments:

Section 2801.2 Permit is hereby revised to read as follows:

2801.2 Permit. Permits shall be required as set forth in Section 105.6 and 105.6.29.

Section 2808.2 Storage site is hereby revised to read as follows:

2808.2 Storage site. Storage sites shall be level and on solid ground, elevated soil lifts or other all-weather surface. Sites shall be thoroughly cleaned and approval obtained from the fire code official before transferring products to the site.

Section 2808.3 Size of piles is hereby revised to read as follows:

2808.3 Size of piles. Piles shall not exceed 15 feet in height, 50 feet in width and 100 feet in length.

Exception: The fire code official is authorized to allow the pile size to be increased where a fire protection plan is provided for approval that includes, but is not limited to, the following:

1. Storage yard areas and materials-handling equipment selection, design and arrangement shall be based upon sound fire prevention and protection principles.
2. Factor that lead to spontaneous heating shall be identified in the plan, and control of the various factors shall be identified and implemented, including provisions for monitoring the internal condition of the pile.
3. The plan shall include means for early fire detection and reporting to the public fire department; and facilities needed by the fire department for fire extinguishment including a water supply and fire hydrants.
4. Fire apparatus access roads around the piles and access roads to the top of the piles shall be established, identified and maintained.
5. Regular yard inspections by trained personnel shall be included as part of an effective fire prevention maintenance program.

Additional fire protection called for in the plan shall be provided and shall be installed in accordance with this code. The increase of the pile size shall be based upon the capabilities of the installed fire protection system and features.

Section 2808.4 Pile Separation is hereby revised to read as follows:

2808.4. Pile separation. Piles shall be separated from adjacent piles by a minimum distance of 20 feet. Additionally, piles shall have a minimum separation of 100 feet from combustible vegetation.

Section 2808.7 Pile fire protection is hereby revised to read as follows:

2808.7 Pile fire protection. Automatic sprinkler protection shall be provided in conveyor tunnels and combustible enclosures that pass under a pile. Combustible conveyor systems and enclosed conveyor systems shall be equipped with an approved automatic sprinkler system. Oscillating sprinklers with a sufficient projectile reach are required to maintain a 40% to 60% moisture content and wet down burning/smoldering areas.

Section 2808.9 Material-handling equipment is hereby revised to read as follows:

2808.9 Material-handling equipment. All material-handling equipment operated by an internal combustion engine shall be provided and maintained with an approved spark arrester. Approved material-handling equipment shall be available for moving wood chips, hogged material, wood fines and raw product during fire-fighting operations.

Section 2808.11 Temperature control is hereby added as follows:

2808.11 Temperature control. The temperature shall be monitored and maintained as specified in Sections 2808.11.1 and 2808.11.2.

Section 2808.11.1 Pile temperature control is hereby added as follows:

2808.11.1 Pile temperature control. Piles shall be rotated when internal temperature readings are in excess of 165 degrees Fahrenheit.

Section 2808.11.2 New material temperature control is hereby added as follows:

2808.11.2 New material temperature control. New loads delivered to the facility shall be inspected and tested at the facility entry prior to taking delivery. Material with temperature exceeding 165 degrees Fahrenheit shall not be accepted on the site. New loads shall comply with the requirements of this chapter and be monitored to verify that the temperature remains stable.

Section 2808.12 Water availability is hereby added as follows:

2808.12 Water Availability. Facilities with over 2500 cubic feet shall provide a water supply. The minimum fire flow shall be no less than 500 GPM @ 20 psi for a minimum of 1 hour duration for pile heights up to 6 feet and 2 hour duration for pile heights over 6 feet. If there is no water purveyor, an alternate water supply with storage tank(s) shall be provided for fire suppression. The water supply tank(s) shall provide a minimum capacity of 2500 gallons per pile (maximum 30,000 gallons) for piles not exceeding 6 feet in height and 5000 gallons per pile (maximum 60,000) for piles exceeding 6 feet in height. Water tank(s) shall not be used for any other purpose unless the required fire flow is left in reserve within the tank at all times. An approved method shall be provided to maintain the required amount of water within the tank(s).

Section 2808.13 Tipping area is hereby added as follows:

2808.13 Tipping areas shall comply with the following:

1. Tipping areas shall not exceed a maximum area of 50 feet by 50 feet.
2. Material within a tipping area shall not exceed 5 feet in height at any time.
3. Tipping areas shall be separated from all piles by a 20 foot wide fire access lane.
4. A fire hydrant or approved fire water supply outlet shall be located within 150 feet of all points along the perimeter of the tipping area.
5. All material within a tipping area shall be processed within 5 days of receipt.

Section 2808.14 Emergency Contact is hereby added as follows:

2808.14 Emergency Contact. The contact information of a responsible person or persons shall be provided to the Fire Department and shall be posted at the entrance to the facility for responding units. The responsible party should be available to respond to the business in emergency situation.

Chapter 29 Manufacture of Organic Coatings is adopted in its entirety without amendments.

Chapter 30 Industrial Ovens is adopted in its entirety without amendments.

Chapter 31 Tents and Other Membrane Structures is adopted in its entirety without amendments.

Chapter 32 High-Piled Combustible Storage is adopted in its entirety without amendments.

Chapter 33 Fire Safety During Construction and Demolition is adopted in its entirety without amendments.

Chapter 34 Tire Rebuilding and Tire Storage is adopted in its entirety without amendments.

Chapter 35 Welding and Other Hot Work is adopted in its entirety without amendments.

Chapter 36 Marinas is adopted in its entirety without amendments.

Chapter 37 Combustible Fibers is adopted in its entirety without amendments.

Chapter 48 Motion Picture and Television Production Studio Sound Stages, Approved Production Facilities and Production Locations is adopted in its entirety without amendments.

Chapter 49 Requirements for Wildland-Urban Interface Fire Areas is adopted in its entirety with the following amendments:

Section 4906.3 Requirements is hereby revised to read as follows:

4906.3 Requirements. Hazardous vegetation and fuels around all applicable buildings and structure shall be maintained in accordance with the following laws and regulations:

1. Public Resources Code, Section 4291.
2. California Code of Regulations, Title 14, Division 1.5, Chapter 7, Subchapter 3, Section 1299 (see guidance for implementation “General Guideline to Create Defensible Space”).
3. California Government Code, Section 51182.
4. California Code of Regulations, Title 19, Division 1, Chapter 7, Subchapter 1, Section 3.07.
5. OCFA Guideline C-05 “Vegetation Management Guideline – Technical Design for New Construction Fuel Modification Plans and Maintenance Program.”

Section 4908 Fuel Modification Requirements for New Construction is hereby added as follows:

4908 Fuel Modification Requirements for New Construction. All new buildings to be built or installed in a Wildfire Risk Area shall comply with the following:

1. Preliminary fuel modification plans shall be submitted to and approved by the fire code official prior to or concurrently with the approval of any tentative map.
2. Final fuel modification plans shall be submitted to and approved by the fire code official prior to the issuance of a grading permit.

3. The fuel modification plans shall meet the criteria set forth in the Fuel Modification Section of OCFA Guideline C-05 "Vegetation Management Guideline – Technical Design for New Construction Fuel Modification Plans and Maintenance Program."

3.1 The fuel modification plan shall include provisions for the maintenance of the fuel modification in perpetuity.

4. The fuel modification plan may be altered if conditions change. Any alterations to the fuel modification areas shall have prior approval from the fire code official.
5. All elements of the fuel modification plan shall be maintained in accordance with the approved plan and are subject to the enforcement process outlined in the Fire Code.

Chapter 50 Hazardous Materials – General Provisions is adopted in its entirety with the following amendments.

Section 5001.5.2 Hazardous Materials Inventory Statement (HMIS) is hereby revised to read as follows:

5001.5.2 Hazardous Materials Inventory Statement (HMIS). Where required by the fire code official, an application for a permit shall include Orange County Fire Authority's Chemical Classification Packet, which shall be completed and approved prior to approval of plans, and/or the storage, use or handling of chemicals on the premises. The Chemical Classification Packet shall include the following information:

1. Product Name.
2. Component.
3. Chemical Abstract Service (CAS) number.
4. Location where stored or used.
5. Container size.
6. Hazard classification.
7. Amount in storage.
8. Amount in use-closed systems.
9. Amount in use-open systems.

Section 5003.1.1.1 Extremely Hazardous Substances is hereby added as follows:

5003.1.1.1 Extremely Hazardous Substances. No person shall use or store any amount of extremely hazardous substances (EHS) in excess of the disclosable amounts (see Health and Safety Code Section 25500 et al) in a residential zoned or any residentially developed property.

Chapter 51 Aerosols is adopted in its entirety without amendments.

Chapter 53 Compressed Gases is adopted in its entirety without amendments.

Chapter 54 Corrosive materials is adopted in its entirety without amendments.

Chapter 55 Cryogenic Fluids is adopted in its entirety without amendments.

Chapter 56 Explosives and Fireworks is adopted in its entirety with the following amendments:

Section 5608.2 Firing is hereby added as follows:

5608.2 Firing. All fireworks displays, regardless of mortar, device, or shell size, shall be electrically fired.

Section 5608.3 Application for Permit is hereby added as follows:

Section 5608.3 Application for Permit. A diagram of the grounds on which the display is to be held showing the point at which the fireworks are to be discharged, the fallout area based on 100 feet per inch of shell size, the location of all buildings, roads, and other means of transportation, the lines behind which the audience will be restrained, the location of all nearby trees, telegraph or telephone line, or other overhead obstructions shall be provided to OCFA.

Chapter 57 Flammable and Combustible Liquids is adopted in its entirety without amendments.

Chapter 58 Flammable Gases and Flammable Cryogenic Fluids is adopted in its entirety without amendments.

Chapter 59 Flammable Solids is adopted in its entirety without amendments.

Chapter 60 Highly Toxic and Toxic Materials is adopted in its entirety without amendments.

Chapter 61 Liquefied Petroleum Gases is adopted in its entirety without amendments.

Chapter 62 Organic Peroxides is adopted in its entirety without amendments.

Chapter 63 Oxidizers, Oxidizing Gases, and Oxiding Cryogenic Fluids is adopted in its entirety without amendments.

Chapter 64 Pyrophoric Materials is adopted in its entirety without amendments.

Chapter 65 Pyroxylin (Cellulose Nitrate) Plastics is adopted in its entirety without amendments.

Chapter 66 Unstable (Reactive) Materials is adopted in its entirety without amendments.

Chapter 67 Water-Reactive Solids and Liquids is adopted in its entirety without amendments.

Chapter 80 Referenced Standards is adopted in its entirety with the following amendments:

NFPA 13, 2016 Edition, Standard for the Installation of Sprinkler Systems is hereby amended as follows:

Section 6.7.3 is hereby revised to read as follows:

6.7.3 Fire department connections (FDC) shall be of an approved type. The location shall be approved and be no more than 150 feet from a public hydrant. The FDC may be located within 150 feet of a private fire hydrant when approved by the fire code official. The size of piping and the number of 2½" inlets shall be approved by the fire code official. If acceptable to the water authority, it may be installed on the backflow assembly. Fire department inlet connections shall be painted OSHA safety red or as approved. When the fire sprinkler density design requires more than 500 gpm (including inside hose stream demand), or a standpipe system is included, four 2½" inlets shall be provided.

Section 8.3.3.1 is hereby revised to read as follows:

8.3.3.1 When fire sprinkler systems are installed in shell buildings of undetermined use (Spec Buildings) other than warehouses (S occupancies), fire sprinklers of the quick-response type shall be used. Use is considered undetermined if a specific tenant/occupant is not identified at the time the fire sprinkler plan is submitted. Sprinklers in light hazard occupancies shall be one of the following:

1. Quick-response type as defined in 3.6.4.8
2. Residential sprinklers in accordance with the requirements of 8.4.5
3. Quick response CMSA sprinklers
4. ESFR sprinklers
5. Standard-response sprinklers used for modifications or additions to existing light hazard systems equipped with standard-response sprinklers
6. Standard-response sprinklers used where individual standard-response sprinklers are replaced in existing light hazard systems

Section 11.1.1.1 is hereby added as follows:

11.1.1.1 When fire sprinkler systems are required in buildings of undetermined use other than warehouses, they shall be designed and installed to have a fire sprinkler density of not less than that required for an Ordinary Hazard Group 2 use, with no reduction(s) in density or design area. Warehouse fire sprinkler systems shall be designed to Figure 16.2.1.3.2 (d) curve "G". Use is considered undetermined if a specific tenant/occupant is not identified at the time the sprinkler plan is submitted. Where a subsequent use or occupancy requires a system with greater capability, it shall be the responsibility of the occupant to upgrade the system to the required density for the new use or occupancy.

Section 11.2.3.1.1.1 is hereby added as follows:

11.2.3.1.1.1 The available water supply for fire sprinkler system design shall be determined by one of the following methods, as approved by the fire code official:

- 1) Subtract the project site elevation from the low water level for the appropriate pressure zone and multiply the result by 0.433;
- 2) Use a maximum of 40 psi, if available;
- 3) Utilize the OCFA water-flow test form/directions to document a flow test conducted by the local water agency or an approved third party licensed in the State of California.

NFPA 13D 2016 Edition, Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes is hereby amended as follows:

Section 7.1.2 is hereby revised to read as follows:

7.1.2 The sprinkler system piping shall not have separate control valves installed unless supervised by a central station, proprietary, or remote station alarm service:

NFPA 14, 2013 Edition, Installation of Standpipe and Hose Systems is hereby amended as follows:

Section 7.3.1.1 is hereby revised to read as follows:

7.3.1.1 Class I and III Standpipe hose connections shall be unobstructed and shall be located not less than 18 inches or more than 24 inches above the finished floor. Class II Standpipe hose connections shall be unobstructed and shall be located not less than 3 feet or more than 5 feet above the finished floor.

NFPA 24, 2016 Edition, Standard for the Installation of Private Fire Service Mains and Their Appurtenances is hereby amended as follows:

Section 6.2.8.1 is hereby added as follows:

6.2.8.1 All indicating valves controlling fire suppression water supplies shall be painted OSHA red.

Exceptions:

1. Brass or bronze valves on sprinkler risers mounted to the exterior of the building may be left unpainted.
2. Where OS&Y valves on the detector check assembly are the only control valves, at least one OS&Y valve shall be painted red.

Section 6.2.9 is hereby revised to read as follows:

All connections to private fire service mains for fire protection systems shall be arranged in accordance with one of the following so that they can be

isolated:

- (1) A post indicator valve installed not less than 40 ft (12 m) from the building
 - (a) For buildings less than 40 ft (12 m) in height, a post indicator valve shall be permitted to be installed closer than 40 ft (12 m) but at least as far from the building as the height of the wall facing the post indicator valve.
- (2) A wall post indicator valve
- (3) An indicating valve in a pit, installed in accordance with Section 6.4
- (4) A backflow preventer with at least one indicating valve not less than 40 ft (12 m) from the building
 - (a) For buildings less than 40 ft (12 m) in height, a backflow preventer with at least one indicating valve shall be permitted to be installed closer than 40 ft (12 m) but at least as far from the building as the height of the wall facing the backflow preventer.
- (5) Control valves installed in a fire-rated room accessible from the exterior
- (6) Control valves in a fire-rated stair enclosure accessible from the exterior

Section 10.1.5 is hereby added as follows:

10.1.5 All ferrous pipe and joints shall be polyethylene encased per AWWA C150, Method A, B, or C. All fittings shall be protected with a loose 8-mil polyethylene tube or sheet. The ends of the tube or sheet shall extend past the joint by a minimum of 12 inches and be sealed with 2 inch wide tape approved for underground use. Galvanizing does not meet the requirements of this section.

Exception: 304 or 316 Stainless Steel pipe and fittings

Section 10.4.1.1 is hereby revised to read as follows:

10.4.1.1 All bolted joint accessories shall be cleaned and thoroughly coated with asphalt or other corrosion-retarding material after installation.

Exception: Bolted joint accessories made from 304 or 316 stainless steel.

Section 10.4.1.1.1 is hereby added as follows:

10.4.1.1.1 All bolts used in pipe-joint assembly shall be 316 stainless steel.

Section 10.4.3.2 is hereby revised to read as follows:

10.4.3.2 Where fire service mains enter the building adjacent to the foundation, the pipe may run under a building to a maximum of 24 inches, as measured from the interior face of the exterior wall to the center of the vertical pipe. The pipe under the building or building foundation shall be 304 or 316 stainless steel and shall not contain mechanical joints or it shall comply with 10.4.3.2.1 through 10.4.3.2.4.

Appendices

Appendix A is deleted in its entirety without amendments.

Appendix B is adopted in its entirety without amendments.

Appendix BB is adopted in its entirety without amendments.

Appendix C is adopted in its entirety without amendments.

Appendix CC is adopted in its entirety without amendments.

Appendix D is deleted in its entirety without amendments.

Appendix E is deleted in its entirety without amendments.

Appendix F is deleted in its entirety without amendments.

Appendix G is deleted in its entirety without amendments.

Appendix H is adopted in its entirety without amendments.

Appendix I is deleted in its entirety without amendments.

Appendix J is deleted in its entirety without amendments.

Appendix K is deleted in its entirety without amendments.

Appendix L is deleted in its entirety without amendments.

Appendix M is deleted in its entirety without amendments.


Appendix N is deleted in its entirety without amendments.

SECTION 4. The City Council finds that this Ordinance is not subject to the California Environmental Quality Act (CEQA) pursuant to California Code of Regulations Title 14, Chapter 3, Sections 15060(c)(2) (the activity will not result in a direct or reasonably foreseeable indirect physical change in the environment) and 15060(c)(3) (the activity is not a project as defined in Section 15371), because it has no potential for resulting in physical change to the environment, directly or indirectly.

SECTION 5. If any section, subsection, subdivision, sentence, clause, phrase, or portion of this Ordinance is, for any reason, held to be invalid or unconstitutional by the decision of any court of competent jurisdiction, such decision shall not affect the validity of the remaining portions of this Ordinance. The City Council hereby declares that it would have adopted this Ordinance and each section, subsection, subdivision, sentence, clause, phrase, or portion thereof, irrespective of the fact that any one or more section, subsection, subdivision, sentence, clause, phrase, or portion thereof be declared invalid or unconstitutional.

SECTION 6. The City Clerk shall certify to the adoption of this Ordinance and cause the same to be posted at the duly designated posting places within the City and published once within fifteen days after passage and adoption as may be required by law; or, in the alternative, the City Clerk may cause to be published a summary of this Ordinance and a certified copy of the text of this Ordinance shall be posted in the Office of the City Clerk five days prior to the date of adoption of this Ordinance; and, within fifteen days after adoption, the City Clerk shall cause to be published, the aforementioned summary and shall post a certified copy of this Ordinance, together with the vote for and against the same, in the Office of the City Clerk.

PASSED, APPROVED, AND ADOPTED this 13th day of December 2016.


DON SEDGWICK , MAYOR

ATTEST:


MELISSA AU-YEUNG, CITY CLERK

STATE OF CALIFORNIA)
COUNTY OF ORANGE) ss
CITY OF LAGUNA HILLS)

I, Melissa Au-Yeung, City Clerk of the City of Laguna Hills, California, DO HEREBY CERTIFY that the foregoing Ordinance No. 2016-8 was duly introduced and placed upon its first reading at a Regular Meeting of the City Council on the 22nd day of November 2016, and that thereafter, said Ordinance was duly adopted and passed at a Regular Meeting of the City Council held on the 13th day of December 2016, by the following vote, to wit:

AYES: Council Members Gilbert, Heft, Kogerman, Mayor Pro Tempore Carruth, and Mayor Sedgwick

NOES: None

ABSENT: None

ABSTAIN: None

(SEAL)


MELISSA AU-YEUNG, CITY CLERK

STATE OF CALIFORNIA)
COUNTY OF ORANGE) ss
CITY OF LAGUNA HILLS)

AFFIDAVIT OF POSTING
AND PUBLICATION

MELISSA AU-YEUNG, being first duly sworn, deposes and says:

That she is the duly appointed and qualified City Clerk of the City of Laguna Hills;

That in compliance with State Laws of the State of California, ORDINANCE NO. 2016-8, being:

AN ORDINANCE OF THE CITY OF LAGUNA HILLS, CALIFORNIA, AMENDING CHAPTER 5-16 (FIRE CODE) OF TITLE 5 (HEALTH AND SANITATION) OF THE LAGUNA HILLS MUNICIPAL CODE AND ADOPTING BY REFERENCE THE 2016 EDITION OF THE CALIFORNIA FIRE CODE INCLUDING APPENDICES B, BB, C, CC, AND H, TOGETHER WITH CERTAIN AMENDMENTS, ADDITIONS, AND DELETIONS THERETO.

on the 2nd day of December 2016, was published in summary in the Saddleback Valley News and on the 23rd day of December 2016, was published in summary in the Saddleback Valley News; and was, in compliance with City Resolution No. 2004-05-25-2, on the 23rd day of November 2016, and the 14th day of December 2016, caused to be posted in three places in the City of Laguna Hills, to wit:

Laguna Hills City Hall
Laguna Hills Community Center
La Paz Center



MELISSA AU-YEUNG, CITY CLERK
Laguna Hills, California